

City of Las Vegas Code and Interpretation

AMEND: 28

DATE: December 19, 2008

CODE: 2006 IBC ☐ 2005 NEC ☐ Local Amendments ☐
 2006 IRC ☐ 2006 UMC ☐ POOL CODE ☐
 2006 IECC ☐ 2006 UPC ☒ MISC. ☐ Admin Code

CODE SECTION: Southern Nevada Plumbing Code 604.1

TOPIC: Plastic pipe shall be limited to buildings defined as combustible construction

PURPOSE/REASON:

INTERPRETATION: All wall penetrations shall be of non-combustible material before transition to plastic on the unconcealed side of the wall (example: plastic P traps at sinks or plastic beverage lines to a soda fountain).

Approved: Chris Knight, CBO